# LISTING SERVICE

**LISTING No.**  7272-0694:253                                                           Page 1 of 1

**CATEGORY:**  Photoelectric Smoke Detector

**LISTEE**:  Fire Control Instruments, *16 Southwest Park, Westwood MA 02090
Contact:  Anthony J. Shalna (781) 471-3000 FAX (781) 471-3099

**DESIGN**:  Model ASD-LS addressable intelligent laser photoelectric type smoke detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:**  24 VDC

**INSTALLATION**:  In accordance with listee's printed installation instructions and applicable codes and ordinances.  Suitable in open areas with air velocities between 0-300 ft/min.

**MARKING**:  Listee's name, model number, electrical rating and UL label.

**APPROVAL**:  Listed as photoelectric smoke detector when used in conjunction with separately listed compatible fire alarm control units and bases.  For wall and ceiling mount.

**XLF**:  7272-1209:220

*Rev. 02-05-2004

Date Issued:  **JUNE 21, 2004**                        *Listing Expires* **June 30, 2005**

*Authorized By:*  **DIANE K. AREND**, *Senior Deputy*
*Program Manager*